

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
5/24/03	5/24/03	36151	Private Property Owner	Seton & Rockrose, Irvine, Orange County	TRW	23,760	An estimated 23,760 gallons of tertiary recycled water was released from an irrigation line break. All 23,760 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.
5/25/03	5/25/03	36152	Private Property Owner	4950 Barranca, Irvine, Riverside County	TRW	3,780	An estimated 3,780 gallons of tertiary recycled water overflowed from an irrigation line break. All 3,780 gallons of the spill discharged into a nearby storm drain. The irrigation line was repaired by private property owner.
5/29/03	5/29/03	36695	IRWD	Reef Pt & Archipelago, Newport Beach, Orange County	TRW	4,500	An estimated 4,500 gallons of tertiary recycled water was released from an irrigation line break. All 4,500 gallons of the spill discharged into a nearby storm drain. The line was repaired by IRWD staff.
6/1/03	6/1/03	36272	IRWD	Deerfield & Culver, Irvine, Orange County	TRW	900	An estimated 900 gallons of tertiary recycled water was released from an irrigation line break. All 900 gallons of the spill discharged into a nearby storm drain. The line was repaired by City of Irvine staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/1/03	6/1/03	36694	City of Huntington Beach	Brookshire & Talbert, Huntington Beach, Orange County	SSO	1,890	An estimated 1,890 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 400 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by city of Huntington Beach staff.
6/2/03	6/2/03	36268	OCSD	Ranchwood & Evening Side, Tustin, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to debris blockage. All 1,000 gallons of the spill was contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up and disinfected by OCSD staff.
6/3/03	6/3/03	36267	Private Property Owner	1301 S Standard Ave, Santa Ana, Orange County	SSO	3,500	An estimated 3,500 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 2,300 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/3/03	6/3/03	36271	Private Property Owner	5 Upland, Irvine, Orange County	TRW	1,350	An estimated 1,350 gallons of tertiary recycled water was released from an irrigation line break. All 1,350 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.
6/7/03	6/7/03	36283	Private Property Owner	6655 Ridge Park Rd, Newport Beach, Orange County	TRW	16,000	An estimated 16,000 gallons of tertiary recycled water was released from an irrigation line break. All 16,000 gallons of the spill discharged into a nearby storm drain and flowed to ocean. The line was repaired by private property owner.
6/10/03	6/10/03	36690	City of La Habra	821 Corto Way, La Habra, Orange County	SSO	550	An estimated 550 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 530 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by City of La Habra staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/13/03	6/13/03	36688	City of Santa Ana	1102 Mantle Ln, Santa Ana, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 500 gallons of the spill was contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Santa Ana staff.
6/18/03	5/24/03	36265	City of Chino Hills	15773 Country Club Dr, Chino Hills, San Bernardino County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a manhole due to root blockage. An unknown amount of the spill was contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City Chino Hills staff.
6/18/03	6/18/03	36692	City of Riverside	Spruce & Mulberry, Riverside, Riverside County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to grease blockage. All 3,000 gallons of the spill were discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Riverside staff.
6/19/03	6/19/03	36693	Private Property Owner	Strawberry Farms Golf Course, Irvine, Orange County	TRW	700	An estimated 700 gallons of tertiary recycled water overflowed from an irrigation line break. All 700 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/21/03	6/21/03	36689	Elsinore Valley Water District	Lighthouse St & Smugglers Cove, Canyon Lake, Riverside County	SSO	25,000	An estimated 25,000 gallons of sewage overflowed from a manhole due to a mechanical failure at a lift station. An unknown amount of the spill was contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The lift station was repaired and the affected area was cleaned up and disinfected by Elsinore Valley staff.
6/23/03	6/23/03	36697	Private Property Owner	Jamboree & Champion Way, Irvine, Orange County	TRW	2,000	An estimated 2,000 gallons of tertiary recycled water was released from an irrigation line break. All 2,000 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.
6/24/03	6/24/03	36691	Private Property Owner	58th & Winchester, Mira Loma, Riverside County	SSO	31,400	An estimated 31,400 gallons of sewage overflowed from a manhole due to construction incident. All 31,400 gallons of the spill was contained on the construction site and then recovered, and discharged into the operational sewer system. The blockage was cleared and the affected area was cleaned up by private property owner.
6/29/03	6/29/03	36696	Private Property Owner	32 Via Barone, Irvine, Orange County	TRW	8,575	An estimated 8,575 gallons of tertiary recycled water was released from an irrigation line break. All 8,575 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/29/03	6/29/03	36700	Private Property Owner	42 Blue Heron, Irvine, Orange County	TRW	26,000	An estimated 26,000 gallons of tertiary recycled water was released from an irrigation line break. All 26,000 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.
6/30/03	6/29/03	36687	Private Property Owner	Mt Baldy Rd, Mt Baldy (Unincorporated), San Bernardino County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to grease blockage. An unknown amount of the spill was contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by private property owner.
6/30/03	6/30/03	36698	Private Property Owner	32 Wildweed, Irvine, Orange County	TRW	3,000	An estimated 3,000 gallons of tertiary recycled water was released from an irrigation line break. All 3,000 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.
6/30/03	6/30/03	36699	Private Property Owner	31 Shady Cyn, Irvine, Orange County	TRW	1,800	An estimated 1,800 gallons of tertiary recycled water was released from an irrigation line break. All 1,800 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/1/03	7/1/03	36683	City of Anaheim	278 N Pearl St, Anaheim, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 10 gallons of the spill was contained and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Anaheim staff.
7/7/03	7/6/03	36686	CMSD	2149 Anniversary Ln, Costa Mesa, Orange County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to lift station failure. Approximately 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The lift station was repaired and the affected area was cleaned up by CMSD staff.
7/10/03	7/10/03	36803	Private Property Owner	38 Santa Cruz Aisle, Irvine, Orange County	TRW	1,800	An estimated 1,800 gallons of tertiary recycled water was released from an irrigation line break. All 1,800 gallons of the spill discharged into a nearby storm drain. The line was repaired by private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/10/03	7/10/03	36823	Cucamonga County Water District	West of Helman between 8th & 7th, Rancho Cucamonga, San Bernardino County	SSO	6,000	An estimated 6,000 gallons of sewage overflowed from a manhole due to construction debris blockage. An unspecified amount of the spill was contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by Cucamonga County Water District staff.
7/11/03	7/7/03	36824	City of Riverside	7020 Crest Ave, Riverside, Riverside County	DS	11,000	An estimated 11,000 gallons of digested sludge (DS) was accidentally released from digester tank breach caused by construction. All 11,000 gallons of the spill were contained on the construction site and then transferred to the dry sludge beds at Riverside Regional Water Quality Control Plant (RRWQCP) to dry. The remaining 50,000 gallons of the sludge in the digester will be transported to the RRWQCP for drying. The containment area was cleaned and disinfected by the City of Riverside staff.
7/13/03	7/13/03	36804	IRWD	2040 Main, Irvine, Orange County	TRW	9,600	An estimated 9,600 gallons of tertiary recycled water was released from an irrigation line break. All 9,600 gallons of the spill discharged into a nearby storm drain. The line was repaired by IRWD staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/14/03	7/14/03	36805	Private Property Owner	13924 Yale Ave, Irvine, Orange County	TRW	3,000	An estimated 3,000 gallons of tertiary recycled water was released from a broken irrigation valve. All 3,000 gallons of the spill discharged into a nearby storm drain. The valve was repaired by private property owner.
7/16/03	7/6/03	36685	San Bernardino Co Water Dist	646 Lytle Creek Rd, Lytle Creek, San Bernardino County	SSO	5,000	An estimated 5,000 gallons of sewage overflowed from a manhole due to lift station failure. An unknown amount of the spill was contained and returned to the operational sewer system, while the rest discharged into a nearby storm drain and flowed to Lytle Creek. The lift station was repaired and the affected area was cleaned up by SBCWD.
7/25/03	7/23/03	36884	Private Property Owner	Hudson Bay & Crown Point Dr, Anaheim, Orange County	SSO	14,865	An estimated 14,865 gallons of sewage overflowed from a private manhole due to tree roots blockage. Approximately 798 gallons of the spill were contained, recovered, and returned to the operational sewer system, while 13,167 gallons of the spill were discharged into the nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by private property owner with assistance of the City of Anaheim staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/25/03	7/25/03	36883	City of Corona	1810 Kapalua Bay Cir, Corona, Riverside County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to construction debris blockage. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by City of Corona staff.